



NMI-Assessment No.: U11-05-E

Date of Expiry:

June 30, 2014

- Regulation Compliance Assessment -

Product Description: Separator tanks for light liquids, e.g. oil and petrol, for use as separator systems; made of polyethylene.

Product Name: Olúskilja 1000 and 1000-U, 1200 and 1200-U, 1400 and 1400-U, i.e. six types.

Assessment Holder: Borgarplast hf., Völuteigi 31-31A, 270 Mosfellsbæ.

Manufacturer: Borgarplast hf., Völuteigi 31-31A, 270 Mosfellsbæ.

Confirm. Documents: An EC Declaration of Conformity (EC-samræmisýfirlýsing) issued by the manufacturer, dated 22 January 2010, declaring conformity with the standard EN 858-1:2002/A1:2004, which is a harmonized European standard, consequently requiring the CE marking of the product, cf. attachment.

Law and Regulation Clauses

The most relevant clauses on which this assessment is based are: 1. The Construction Act, no. 160/2010, art. 39. 2. The Building Regulation, no. 441/1998, art. 3 and 120. 3. The Regulation on Commercial Transactions of Building Products, no. 431/1994, art. 3 and 4.

Provisions, Reservations, Comments and Notes

- A clearly visible nameplate of durable material shall be fixed to each separator showing the identification of the manufacturer, the number of the EN standard in reference, class (I or II), nominal size, the volume of the separator and the sludge trap, the light liquid storage capacity, the depth of the maximum storage quantity and the year of manufacture; furthermore, the **CE marking** symbol shall be correctly depicted.
- The clauses of the product standard in reference require neither a notified body nor in general an independent certification body and, accordingly, no certificate is issued.
- This assessment covers only the product described by the EC Declaration of Conformity in reference.
- No evidence is available for the existence of any documents specific for Iceland defining functional requirements for separator tank systems for the use in question.
- The design and installation shall be in accordance with the manufacturer's description; the separator tank system, where installed, must not be overloaded with respect to their properties and conditions for use as these are specified by the manufacturer and described by the standard in reference.


Assessment Statement

The confirmation documents referred to above do not appear to indicate the products in question to be in any violation of Icelandic regulations or legal acts when used as separator tank systems. It has been ascertained that the manufacturer fulfils the requirements for the CE marking of the products. This assessment is a renewal of assessment no. U10-02.

This assessment remains valid only as long as the product itself or its marking remains unchanged, as well as the clauses of the laws, regulations and standards relevant for the product and its use.

Date of issue: June 29, 2011


Rögnvaldur S. Gíslason,
Certification Chief.


Jón Sigurjónsson,
Chief Engineer.

ATTACHMENT: EC Declaration of Conformity by the manufacturer (one page).